

**CITY OF NORTH LAS VEGAS UTILITY DEPT. DISCLAIMER :**  
 A STATEMENT OF UNDERSTANDING BETWEEN THE CITY OF NORTH LAS VEGAS UTILITY DEPARTMENT (CITY) AND ANY AND ALL SUBSEQUENT USERS OF INFORMATION OBTAINED HEREFROM:  
 THE PLANS AND SUPPORTING INFORMATION IS FURNISHED BY THE CITY, AND IS ACCEPTED/USED BY THE RECIPIENT WITH THE UNDERSTANDING THAT THE CITY MAKES NOT WARRANTIES, EXPRESS OR IMPLIED, CONCERNING THE ACCURACY, COMPLETENESS, RELIABILITY, OR SUITABILITY OF SAID PLANS OR ANY SUPPORTING DATA AND FURTHER UNDERSTANDS THAT ALL USERS ARE ACTING AT THEIR OWN RISK.  
 THE CITY SHALL BE UNDER NO LIABILITY WHATSOEVER RESULTING FROM ANY USE OF THIS INFORMATION. THIS INFORMATION SHOULD NOT BE RELIED UPON AS THE SOLE BASIS FOR EXISTING WATER AND/OR SEWER LOCATIONS. THE ENGINEER SHALL CHECK AND VERIFY ALL DIMENSIONS AND LOCATIONS OF EXISTING UTILITIES.

**C.N.L.V. WATER SERVICE RULES AND REGULATIONS/FIRE CODE REQUIREMENTS**  
 TWO (2) SOURCES OF WATER SUPPLY ARE REQUIRED FOR ANY DEVELOPMENT WITH ANY COMBINATION OF MORE THAN THREE (3) FIRE HYDRANTS (INCLUDING PUBLIC AND PRIVATE) OR FIRE SERVICES.

**SIGHT VISIBILITY NOTE**  
 NO WALLS, FENCES, SHRUBS, UTILITY APPURTENANCES OR ANY OTHER OBJECT, OTHER THAN TRAFFIC CONTROL DEVICES, FIRE HYDRANTS, TREES, AND STREET LIGHT POLES, MAY BE CONSTRUCTED OR INSTALLED WITHIN THE SIGHT VISIBILITY ZONE UNLESS SAID OBJECT IS MAINTAINED AT LESS THAN 24 INCHES IN HEIGHT, MEASURED FROM TOP OF CURB, OR WHERE NO CURB EXISTS, A HEIGHT OF 27 INCHES MEASURED FROM THE TOP OF ADJACENT ASPHALT, GRAVEL OR PAVEMENT STREET SURFACE. THIS RESTRICTION EXTENDS ALONG THE SIGHT VISIBILITY LINE THROUGH LANDSCAPED MEDIANS. SEE DETAIL SHEET C5.4 FOR ALL SITE VISIBILITY ZONE DIMENSIONS.

**CONDITIONAL APPROVAL OF VALVED OUTLET (6" AND LARGER)**  
 THE WATER PLANS SHOW ONE OR MORE VALVED OUTLETS EXTENDING OUT OF PAVED AREAS. INSTALLATION OF THESE OUTLETS IS ACCEPTABLE, HOWEVER, IF THE OUTLETS ARE INCORRECTLY LOCATED OR NOT USED FOR ANY REASON WHEN THE PROPERTY IS ACTUALLY DEVELOPED, THE DEVELOPER SHALL ABANDON THE OUTLETS AT THE CONNECTION TO THE ACTIVE MAIN IN ACCORDANCE WITH THE CITY'S STANDARDS AND AT THE DEVELOPER'S EXPENSE. APPROVAL OF THE VALVED OUTLET DOES NOT PROVIDE OR IMPLY A WATER COMMITMENT.

**WATER MAIN JOINT DEFLECTION NOTE**  
 AS A PART OF THE INSPECTION REQUIREMENT, A REGISTERED PROFESSIONAL LAND SURVEYOR SHALL CONFIRM IN WRITING/ STAMPED (OFFICIAL CONFIRMATION) THAT THE HORIZONTAL/ VERTICAL DEFLECTIONS OF PIPE PLACEMENT ARE WITHIN THE MAXIMUM ALLOWABLE JOINT DEFLECTION PER UDACS 2.07.01. CITY WILL ACQUIRE GPS POINTS OF THE INSTALLED WATER LINE UPON RECEIPT OF AN OFFICIAL CONFIRMATION FROM THE SURVEYOR.

ONLY FIRE PREVENTION	DATE
----------------------	------

Call before you Dig  
and other underground  
utilities are in your way.



1-800-227-2600

**FAST**  
Call before you  
UnderGround

1-702-432-5300

CALL BEFORE YOU  
OVERHEAD

1-702-227-2929



FILE LOCATION: \\LAW\_C:\In\956888010-QuikTrip 7235\CAD\Plan\Sheets\89-7235 Civil-CIP.dwg TAB NAME: CIP150 USER: donnie.koch SAVED: 11/19/2022 9:51 AM PLOTTED: 11/19/2022 10:47 AM